

## DECLARATIE, CERTIFICAT DE CONFORMITATE

Orient Ceramic, cu sediul in Constanta, Str.Interioara2 Nr.1 , J13/775/2005, RO 17352940, asiguram, garantam si declaram pe propria raspundere, conform prevederilor Art.5 din HG nr. 1022/2002 privind regimul produselor si serviciilor care pot pune in pericol viata, sanatatea , securitatea si protectia mediului, ca produsele:

<b>FAIANTA ACC1824 L ROYAL BEJ 30X45 CM - GLAZURATA INTERIOR RECTIFICATA LUCIOASA</b>
<b>FAIANTA ACC1824 D ROYAL MARO 30X45 CM - GLAZURATA INTERIOR RECTIFICATA LUCIOASA</b>
<b>FAIANTA ACC1824 HL1 ROYAL 3D 30X45 CM - GLAZURATA INTERIOR RECTIFICATA LUCIOASA</b>
<b>GRESIE ACC1824 F ROYAL MARO 30X30 CM - GLAZURATA INTERIOR RECTIFICATA MATA, SUPRAFATA ANTIALUNECARE</b>

au urmatoarele caracteristici comunicate de producator:

### QUALITY CERTIFICATE REPORT

No.	PROPERTIES	REQUIREMENTS ISO 10545	RESULT
1	Size (%)	Length: $\pm 0.50$	+0.06
		Width: $\pm 0.50$	+0.02
2	Thickness (%)	$\pm 10$	$\pm 1.05$
3	Straightness of sides(%)	$\pm 0.30$	-0.04 ~ +0.05
4	Rectangularity (%)	$\pm 0.50$	-0.05 ~ +0.04
5	Center curvature (%)	$\pm 0.30$	+ 0.05
6	Edge curvature	$\pm 0.30$	+ 0.06
7	Warpage (%)	$\pm 0.50$	+ 0.05
8	Surface quality	95	95
9	Water absorption (%)	average $10 < E < 20$	9
10	Breaking strength (N)	If thickness $\geq 7.5\text{mm}$ , Average $\geq 600$ ,	809.38
11	Modulus of rupture (Mpa)	Average $\geq 15$ , individual $\geq 12$	16.59
12	Thermal shock resistance 15/145° C	10 Cycle Pass	Passed
13	Resistance to house hold chemical reagent	Not lower than Grade: GB	Class GA
14	Resistance to staining	Not lower than Grade 3 for glazed tile	Class 5
15	Resistance to acid (in 3% HCl liquor four days)	Class GLB	Class GLA
16	Resistance to alkali ( in 30g LKOH liquor four days)	Class GLB	Class GLA
17	Abrasion resistance floor tile 30x30 cm	PEI I-V	PEI I
18	Anti-slip degree floor tile 30x30 cm	R 9-12	R 9

nu pun in pericol viata, sanatatea, securitatea muncii si protectia mediului si sunt in conformitate cu normele in vigoare din punct de vedere al calitatii produsului.

