

CE TEST CERTIFICATE

FOR PERFORMANCE CHARACTERISTICS OF CONSTRUCTION PRODUCTS FOR THE CE MARKING

FLO-22-10-06-01

Products: Wall covering tiles "Rocko tiles", Thickness: 4 mm
Surface structures: FN, PT (UV-laquered PVC)
suitable also for the installation as floor covering

Producer: Kronoflooring Sp. z o.o.
ul. Przemysłowa 10
38-200 JASŁO
POLAND

Order: Determination of the anti-sliding property according to EN 13893:2002-11 /
Classification according to EN 14041:2004+AC:2005+AC:2006

Test reports: 2718587, 2719182, 2721545

Test results:

Properties	Declaration according to EN 14041:2004+AC:2005+AC:2006
Reaction to fire performance according to EN ISO 9239-1:2010 and EN ISO 11925-2:2011; Classification according to EN 13501-1:2010 - Critical heat flow - Smoke production	B _{fl} - s1*
Anti-sliding property according to EN 13893:2002-11	class DS
Thermal resistance according to EN 12667:2001	0,008 (m ² K)/W

* Valid on mineral subfloor in end use application, using adhesive or not.

Dresden, 06/10/2022

i.v. Adam Mosler

Head of laboratory



i.v. [Signature]

Engineer in charge